

Updated Bryant / BDP Orifice Sizes and Manifold Pressures
provided by Contractors HVAC (04/2006)

Location/Specific Gravity	Specific Gravity	Heat Content	Elevation	Orifice Size/Manifold Pressure(Low Heat Manifold Pressure)							
				Furnace Model Number							
				310A/311A	312A/315A	383KAV/ 395CAV/PG8U	373LAV/ 376CAV/PG8D	350MAV/ PG9M	330AAV/ 333BAV	331AAV	355MAV
SALT LAKE/.60/890	0.6	890	4350	43/2.7	45/3.5(1.5)	43/2.4	43/2.7	45/3.4	47/3.5(1.5)	46/3.5(1.5)	45/3.4(1.4)
Alta/.60/755	0.6	755	8600	43/2.1	47/3.5(1.5)	48/3.6 *	43/2.1	45/3.4	48/3.5(1.5)	48/3.5(1.5)	45/3.4(1.4)
Snowbird/.60/778	0.6	778	7800	43/2.3	46/3.5(1.5)	43/2.1	43/2.3	45/3.6	48/3.5(1.5)	47/3.5(1.5)	45/3.6(1.5)
HEBER/.60/843	0.6	843	5660	43/2.6	46/3.5(1.5)	43/2.4	43/2.6	45/3.5	47/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Coalville/.60/833	0.6	833	6000	43/2.6	46/3.5(1.5)	43/2.2	43/2.6	45/3.7	48/3.5(1.5)	47/3.5(1.5)	45/3.7(1.6)
Deer Valley/.60/786	0.6	786	7500	43/2.2	46/3.5(1.5)	43/2.1	43/2.3	45/3.6	48/3.5(1.5)	47/3.5(1.5)	45/3.6(1.5)
Francis/.60/815	0.6	815	6560	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Jeremy Ranch/.60/821	0.6	821	6400	43/2.3	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Kamas/.60/833	0.6	833	6000	43/2.6	46/3.5(1.5)	43/2.5	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Midway/.60/847	0.6	847	5550	43/2.6	46/3.5(1.5)	43/2.4	43/2.6	45/3.5	47/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Oakley/.60/818	0.6	818	6475	43/2.2	46/3.5(1.5)	43/2.2	43/2.5	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Park City/.60/803	0.6	803	7000	43/2.5	46/3.5(1.5)	43/2.3	43/2.5	45/3.7	48/3.5(1.5)	47/3.5(1.5)	45/3.7(1.6)
Pinebrook/.60/821	0.6	821	6400	43/2.3	46/3.5(1.5)	43/2.2	43.2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Summit Park/.60/803	0.6	803	7000	43/2.5	46/3.5(1.5)	43/2.3	43/2.5	45/3.7	48/3.5(1.5)	47/3.5(1.5)	45/3.7(1.6)
Wanship/.60/837	0.6	837	5900	43/2.6	46/3.5(1.5)	43/2.5	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Woodland/.60/833	0.6	833	6000	43/2.7	46/3.5(1.5)	43/2.5	43/2.6	45/3.7	48/3.5(1.5)	47/3.5(1.5)	45/3.7(1.6)
TOOELE/.60/867	0.6	867	4900	43/2.8	46/3.5(1.5)	43/2.6	43/2.9	45/3.6	47/3.5(1.5)	46/3.5(1.5)	45/3.6(1.5)
Grantsville/.60/883	0.6	883	4400	43/2.7	46/3.5(1.5)	43/2.6	43/2.8	45/3.6	47/3.5(1.5)	46/3.5(1.5)	45/3.6(1.5)
PRICE/.62/896	0.62	896	5680	43/2.3	47/3.5(1.5)	43/2.2	43/2.4	45/3.3	48/3.5(1.5)	47/3.5(1.5)	45/3.3(1.4)
Altamont/.62/896	0.62	896	5700	43/2.3	47/3.5(1.5)	43/2.2	43/2.4	45/3.3	48/3.5(1.5)	47/3.5(1.5)	45/3.3(1.4)
Bonanza/.62/904	0.62	904	5450	43/2.3	47/3.5(1.5)	43/2.2	43/2.4	45/3.3	48/3.5(1.5)	47/3.5(1.5)	45/3.3(1.4)
Castledale/.56/800	0.56	800	5660	43/2.7	45/3.5(1.5)	43/2.5	43/2.7	45/3.6	47/3.5(1.5)	46/3.5(1.5)	45/3.6(1.5)
Ferron/.56/843	0.56	843	5930	43/2.4	47/3.5(1.5)	43/2.2	43/2.4	45/3.3	48/3.5(1.5)	47/3.5(1.5)	45/3.3(1.4)
Helper/.62/891	0.62	891	5900	43/2.3	47/3.5(1.5)	43/2.2	43/2.4	45/3.3	48/3.5(1.5)	47/3.5(1.5)	45/3.3(1.4)
Roosevelt/.62/913	0.62	913	5150	43/2.3	47/3.5(1.5)	43/2.2	43/2.4	45/3.2	48/3.5(1.5)	47/3.5(1.5)	45/3.2(1.3)
Vernal/.62/908	0.62	908	5300	43/2.3	47/3.5(1.5)	43/2.2	43/2.4	45/3.3	48/3.5(1.5)	47/3.5(1.5)	45/3.3(1.4)
PROVO/.56/868	0.56	868	4350	43/2.7	46/3.5(1.5)	43/2.4	43/2.6	45/3.5	47/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Birds Eye/.56/834	0.56	834	5400	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Cedar Fort/.56/851	0.56	851	5125	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.3	48/3.5(1.5)	47/3.5(1.5)	45/3.3(1.4)

*Orifice Change Required

Note 1: 90% Bryant and Payne furnaces AGA approved for 2%/1000 ft deration.
Note 2: All Bryant and Payne furnaces, except 2-stage, AGA approved to derate - adjust gas pressure down to as low as 2.0 in. W.C. and no lower.

Updated Bryant / BDP Orifice Sizes and Manifold Pressures
provided by Contractors HVAC (04/2006)

Location/Specific Gravity	Specific Gravity	Heat Content	Elevation	Orifice Size/Manifold Pressure(Low Heat Manifold Pressure)							
				Furnace Model Number							
				310A/311A	312A/315A	383KAV/ 395CAV/PG8U	373LAV/ 376CAV/PG8D	350MAV/ PG9M	330AAV/ 333BAV	331AAV	355MAV
Nephi/.56/842	0.56	842	5100	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.3	47/3.5(1.5)	47/3.5(1.5)	45/3.3(1.4)
Santaquin/.56/849	0.56	849	4900	43/2.7	46/3.5(1.5)	43/2.5	43/2.8	45/3.6	47/3.5(1.5)	47/3.5(1.5)	45/3.6(1.5)
Woodland Hills/.56/828	0.56	828	5650	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
OGDEN/.60/890	0.6	890	4350	43/2.6	45/3.5(1.5)	43/2.4	43/2.6	45/3.5	47/3.5(1.5)	46/3.5(1.5)	45/3.5(1.5)
Morgan/.60/862	0.6	862	5000	43/2.8	45/3.5(1.5)	43/2.7	43/2.9	45/3.7	47/3.5(1.5)	46/3.5(1.5)	45/3.7(1.6)
Ogden Valley/.60/862	0.6	862	5000	43/2.8	45/3.5(1.5)	43/2.7	43/2.9	45/3.7	47/3.5(1.5)	46/3.5(1.5)	45/3.7(1.6)
LAYTON/.60/890	0.6	890	4350	43/2.6	45/3.5(1.5)	43/2.4	43/2.7	45/3.5	47/3.5(1.5)	46/3.5(1.5)	45/3.5(1.5)
BRIGHAM CITY/.60/890	0.6	890	4220	43/2.6	45/3.5(1.5)	43/2.4	43/2.7	45/3.5	47/3.5(1.5)	46/3.5(1.5)	45/3.5(1.5)
Mantua/.60/834	0.6	834	6000	43/2.7	46/3.5(1.5)	43/2.5	43/2.7	45/3.6	48/3.5(1.5)	47/3.5(1.5)	45/3.6(1.5)
Tremonton/.60/890	0.6	890	4325	43/2.6	45/3.5(1.5)	43/2.4	43/2.6	45/3.5	47/3.5(1.5)	46/3.5(1.5)	45/3.5(1.5)
LOGAN/.60/880	0.6	880	4500	43/2.8	45/3.5(1.5)	43/2.6	43/2.8	45/3.6	47/3.5(1.5)	46/3.5(1.5)	45/3.6(1.5)
FILLMORE/.60/885	0.6	885	5100	43/2.4	46/3.5(1.5)	43/2.1	43/2.4	45/3.2	48/3.5(1.5)	47/3.5(1.5)	45/3.2(1.3)
Beaver/.60/862	0.6	862	5900	43/2.5	46/3.5(1.5)	43/2.4	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Delta/.60/900	0.6	900	4650	43/2.6	46/3.5(1.5)	43/2.4	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Holden/.60/883	0.6	883	5150	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.2	48/3.5(1.5)	47/3.5(1.5)	45/3.2(1.3)
Kanosh/.60/882	0.6	882	5200	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.2	48/3.5(1.5)	47/3.5(1.5)	45/3.2(1.3)
Leamington/.60/898	0.6	898	4700	43/2.6	46/3.5(1.5)	43/2.4	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Lynndyl/.60/895	0.6	895	4800	43/2.6	46/3.5(1.5)	43/2.4	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Meadow/.60/895	0.6	895	4800	43/2.6	46/3.5(1.5)	43/2.4	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Milford/.60/889	0.6	889	4950	43/2.6	46/3.5(1.5)	43/2.4	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Minersville/.60/879	0.6	879	5300	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.2	48/3.5(1.5)	47/3.5(1.5)	45/3.2(1.3)
Oak City/.60/885	0.6	885	5105	43/2.3	46/3.5(1.5)	43/2.2	43/2.4	45/3.2	48/3.5(1.5)	47/3.5(1.5)	45/3.2(1.3)
Scipio/.60/879	0.6	879	5300	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.2	48/3.5(1.5)	47/3.5(1.5)	45/3.2(1.3)
RICHFIELD/.56/838	0.56	838	5290	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Aurora/.56/841	0.56	841	5150	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Axtell/.56/841	0.56	841	5150	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Centerfield/.56/842	0.56	842	5100	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Central-Anna/.56/836	0.56	836	5340	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Chester/.56/832	0.56	832	5510	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)

*Orifice Change Required

Note 1: 90% Bryant and Payne furnaces AGA approved for 2%/1000 ft deration.
Note 2: All Bryant and Payne furnaces, except 2-stage, AGA approved to derate - adjust gas pressure down to as low as 2.0 in. W.C. and no lower.

Updated Bryant / BDP Orifice Sizes and Manifold Pressures
provided by Contractors HVAC (04/2006)

Location/Specific Gravity	Specific Gravity	Heat Content	Elevation	Orifice Size/Manifold Pressure(Low Heat Manifold Pressure)							
				Furnace Model Number							
				310A/311A	312A/315A	383KAV/ 395CAV/PG8U	373LAV/ 376CAV/PG8D	350MAV/ PG9M	330AAV/ 333BAV	331AAV	355MAV
Circleville/.56/815	0.56	815	6060	43/2.2	46/3.5(1.5)	43/2.1	43/2.3	45/3.3	48/3.5(1.5)	47/3.5(1.5)	45/3.3(1.4)
Elsinore/.56/836	0.56	836	5330	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Ephraim/.56/831	0.56	831	5515	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Fairview/.56/819	0.56	819	5960	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Fayette/.56/844	0.56	844	5050	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Fountain/.56/825	0.56	825	5750	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Glenwood/.56/838	0.56	838	5300	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Gunnison/.56/842	0.56	842	5100	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Indianola/.56/818	0.56	818	6000	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Joseph/.56/834	0.56	834	5435	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Junction/.56/817	0.56	817	6020	43/2.2	46/3.5(1.5)	43/2.1	43/2.2	45/3.3	48/3.5(1.5)	47/3.5(1.5)	45/3.3(1.4)
Manti/.56/830	0.56	830	5560	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Marysville/.56/820	0.56	820	5920	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.6	48/3.5(1.5)	47/3.5(1.5)	45/3.6(1.5)
Mayfield/.56/831	0.56	831	5540	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Monroe/.56/835	0.56	835	5375	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Moroni/.56/831	0.56	831	5520	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Mount Pleasant/.56/822	0.56	822	5840	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.6	48/3.5(1.5)	47/3.5(1.5)	45/3.6(1.5)
Panguich/.56/797	0.56	797	6624	43/2.4	46/3.5(1.5)	43/2.5	43/2.3	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Redmond/.56/842	0.56	842	5100	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Salina/.56/841	0.56	841	5140	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Sevier/.56/830	0.56	830	5542	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Sigurd/.56/838	0.56	838	5260	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Spring City/.56/823	0.56	823	5800	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Sterling/.56/830	0.56	830	5560	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Venice/.56/838	0.56	838	5260	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Wales/.56/832	0.56	832	5500	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
CEDAR CITY/.56/825	0.56	825	5720	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Brian Head/.56/708	0.56	708	9800	48/3.6*	48/3.5(1.5)	48/3.2 *	48/3.7 *	45/3.5	49/3.5(1.5)	48/3.5(1.5)	45/3.5(1.5)
Enoch/.56/825	0.56	825	5720	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)

*Orifice Change Required

Note 1: 90% Bryant and Payne furnaces AGA approved for 2%/1000 ft deration.
Note 2: All Bryant and Payne furnaces, except 2-stage, AGA approved to derate - adjust gas pressure down to as low as 2.0 in. W.C. and no lower.

Updated Bryant / BDP Orifice Sizes and Manifold Pressures
provided by Contractors HVAC (04/2006)

Location/Specific Gravity	Specific Gravity	Heat Content	Elevation	Orifice Size/Manifold Pressure(Low Heat Manifold Pressure)							
				Furnace Model Number							
				310A/311A	312A/315A	383KAV/ 395CAV/PG8U	373LAV/ 376CAV/PG8D	350MAV/ PG9M	330AAV/ 333BAV	331AAV	355MAV
Enterprise/.60/879	0.6	879	5300	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.0	48/3.5(1.5)	47/3.5(1.5)	45/3.0(1.2)
Hamilton Fort/.56/828	0.56	828	5647	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Kanarraville/.56/832	0.56	832	5480	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
New Castle/.60/882	0.6	882	5200	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.2	48/3.5(1.5)	47/3.5(1.5)	45/3.2(1.3)
Paragonah/.56/822	0.56	822	5860	43/2.5	46/3.5(1.5)	43/2.3	43/2.6	45/3.5	48/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Parowan/.56/815	0.56	815	6060	43/2.2	46/3.5(1.5)	43/2.1	43/2.2	45/3.3	48/3.5(1.5)	47/3.5(1.5)	45/3.3(1.4)
Summit/.56/917	0.56	917	5950	43/2.1	48/3.5(1.5)	48/3.5 *	43/2.0	45/2.9	49/3.5(1.5)	49/3.5(1.5)	45/2.9(1.2)
ST. GEORGE/.56/919	0.56	919	2760	43/3.0	45/3.5(1.5)	43/2.8	43/3.0	45/3.6	47/3.5(1.5)	46/3.5(1.5)	45/3.6(1.5)
Central/.60/882	0.6	882	5200	43/2.4	46/3.5(1.5)	43/2.2	43/2.4	45/3.2	48/3.5(1.5)	47/3.5(1.5)	45/3.2(1.3)
Hurricane/.56/903	0.56	903	3250	43/2.8	45/3.5(1.5)	43/2.6	43/2.8	45/3.5	47/3.5(1.5)	46/3.5(1.5)	45/3.5(1.5)
Ivins/.56/912	0.56	912	2960	43/3.2	45/3.5(1.5)	43/2.9	43/3.2	45/3.6	47/3.5(1.5)	46/3.5(1.5)	45/3.6(1.5)
LaVerkin/.56/906	0.56	906	3200	43/2.8	45/3.5(1.5)	43/2.6	43/2.8	45/3.5	47/3.5(1.5)	46/3.5(1.5)	45/3.5(1.5)
Leeds/.56/896	0.56	896	3460	43/2.8	45/3.5(1.5)	43/2.6	43/2.8	45/3.5	47/3.5(1.5)	46/3.5(1.5)	45/3.5(1.5)
Santa Clara/.56/919	0.56	919	2760	43/3.0	45/3.5(1.5)	43/2.8	43/3.0	45/3.6	47/3.5(1.5)	46/3.5(1.5)	45/3.6(1.5)
Springdale/.56/883	0.56	883	3913	43/2.9	45/3.5(1.5)	43/2.7	43/3.0	45/3.5	47/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Toquerville/.56/886	0.56	886	3760	43/2.9	45/3.5(1.5)	43/2.7	43/3.0	45/3.5	47/3.5(1.5)	47/3.5(1.5)	45/3.5(1.5)
Veyo/.60/905	0.6	905	4500	43/2.6	46/3.5(1.5)	43/2.4	43/2.6	45/3.4	48/3.5(1.5)	47/3.5(1.5)	45/3.4(1.4)
Washington/.56/919	0.56	919	2760	43/3.0	45/3.5(1.5)	43/2.8	43/3.0	45/3.6	47/3.5(1.5)	46/3.5(1.5)	45/3.6(1.5)
ROCK SPRINGS/.62/877	0.62	877	6300	43/2.2	47/3.5(1.5)	48/3.8 *	43/2.2	45/3.2	48/3.5(1.5)	48/3.5(1.5)	45/3.2(1.3)
Baggs/.62/878	0.62	878	6250	43/2.2	47/3.5(1.5)	48/3.8 *	43/2.2	45/3.2	48/3.5(1.5)	48/3.5(1.5)	45/3.2(1.3)
Granger/.62/878	0.62	878	6260	43/2.2	47/3.5(1.5)	48/3.8 *	43/2.2	45/3.2	48/3.5(1.5)	48/3.5(1.5)	45/3.2(1.3)
Green River/.62/877	0.62	877	6300	43/2.2	47/3.5(1.5)	48/3.8 *	43/2.2	45/3.2	48/3.5(1.5)	48/3.5(1.5)	45/3.2(1.3)
Wamsutter/.62/862	0.62	862	6740	43/2.3	47/3.5(1.5)	43/2.1	43/2.3	45/3.3	48/3.5(1.5)	48/3.5(1.5)	45/3.3(1.4)
EVANSTON/.60/809	0.6	809	6800	43/2.5	46/3.5(1.5)	43/2.3	43/2.5	45/3.6	48/3.5(1.5)	47/3.5(1.5)	45/3.6(1.5)
Big Piney/.62/860	0.62	860	6820	43/2.3	47/3.5(1.5)	43/2.1	43/2.3	45/3.3	48/3.5(1.5)	48/3.5(1.5)	45/3.3(1.4)
LaBarge/.62/867	0.62	867	6600	43/2.3	47/3.5(1.5)	48/3.8 *	43/2.2	45/3.3	48/3.5(1.5)	48/3.5(1.5)	45/3.3(1.4)
Lyman/.62/863	0.62	863	6700	43/2.3	47/3.5(1.5)	48/3.8 *	43/2.2	45/3.3	48/3.5(1.5)	48/3.5(1.5)	45/3.3(1.4)

*Orifice Change Required

Note 1: 90% Bryant and Payne furnaces AGA approved for 2%/1000 ft deration.
Note 2: All Bryant and Payne furnaces, except 2-stage, AGA approved to derate - adjust gas pressure down to as low as 2.0 in. W.C. and no lower.